

Test Certificate

Testing Date Range From: 15/03/2018 To: 15/03/2018
*Note - Items were not function tested

Client: Security Smart Ltd	Site: 44 Gillender St	Location: OFFICE
Asset ID: 97105	Description: POWER LEAD	Make:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Model:
Comments:		

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
IEC Lead Continuity	15/03/2018	0.11	ohm	Pass
Insulation Voltage	15/03/2018	500	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
IEC Lead Polarity	15/03/2018			Pass
Overall: Pass				

Asset ID: 97106	Description: PC	Make: HP	Model: PAVILION
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 97107	Description: SPEAKERS	Make: LOGITECH	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 97108	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
IEC Lead Continuity	15/03/2018	0.1	ohm	Pass
Insulation Voltage	15/03/2018	500	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
IEC Lead Polarity	15/03/2018			Pass
Overall: Pass				

Asset ID: 97109	Description: LAPTOP CHARGER	Make: HP	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information

Signed By: 



Test Certificate

Testing Date Range From: 15/03/2018 To: 15/03/2018
*Note - Items were not function tested

Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 97111	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
IEC Lead Continuity	15/03/2018	0.09	ohm	Pass
Insulation Voltage	15/03/2018	500	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
IEC Lead Polarity	15/03/2018			Pass
Overall: Pass				

Asset ID: 97112	Description: PRINTER	Make: BROTHER	Model: HL 2250DN
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Earth Continuity	15/03/2018	< 0.010	ohm	Pass
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 97113	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
IEC Lead Continuity	15/03/2018	0.11	ohm	Pass
Insulation Voltage	15/03/2018	500	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
IEC Lead Polarity	15/03/2018			Pass
Overall: Pass				

Asset ID: 97114	Description: PRINTER	Make: XEROX	Model: WORKCENTRE 6605
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Earth Continuity	15/03/2018	0.03	ohm	Pass
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 97115	Description: MICROWAVE	Make: KENWOOD	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass

Signed By: 

Test Certificate

Testing Date RangeFrom: 15/03/2018 To: 15/03/2018
*Note - Items were not function tested

Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Earth Continuity	15/03/2018	< 0.010	ohm	Pass
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	2.49	MOhm	Pass

Overall: Pass

Asset ID: 97116	Description: FRIDGE	Make: HOOVER	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Earth Continuity	15/03/2018	< 0.010	ohm	Pass
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 97117	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
IEC Lead Continuity	15/03/2018	0.1	ohm	Pass
Insulation Voltage	15/03/2018	500	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass
IEC Lead Polarity	15/03/2018			Pass

Overall: Pass

Asset ID: 97118	Description: PC	Make: HP	Model: ENVY
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 97119	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass

Overall: Pass

Signed By: 

Test Certificate

Testing Date RangeFrom: 15/03/2018 To: 15/03/2018
*Note - Items were not function tested

Asset ID: 97120	Description: LAPTOP CHARGER	Make: HP	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	
Test Type	Date	Result	Unit Status
Plug	15/03/2018		Pass
Flex	15/03/2018		Pass
Enclosure	15/03/2018		Pass
Environment	15/03/2018		Pass
Socket	15/03/2018		Pass
Switch	15/03/2018		Pass
Voltage	15/03/2018	230	V Information
Insulation Voltage	15/03/2018	250	V Information
Insulation	15/03/2018	> 19.99	MOhm Pass
Overall: Pass			

Asset ID: 97121	Description: SHREDDER	Make: FELLOWES	Model: M 3C
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	
Test Type	Date	Result	Unit Status
Plug	15/03/2018		Pass
Flex	15/03/2018		Pass
Enclosure	15/03/2018		Pass
Environment	15/03/2018		Pass
Socket	15/03/2018		Pass
Switch	15/03/2018		Pass
Voltage	15/03/2018	230	V Information
Insulation Voltage	15/03/2018	250	V Information
Insulation	15/03/2018	> 19.99	MOhm Pass
Overall: Pass			

Asset ID: 97122	Description: LAMINATOR	Make: LEITZ	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	
Test Type	Date	Result	Unit Status
Plug	15/03/2018		Pass
Flex	15/03/2018		Pass
Enclosure	15/03/2018		Pass
Environment	15/03/2018		Pass
Socket	15/03/2018		Pass
Switch	15/03/2018		Pass
Voltage	15/03/2018	230	V Information
Insulation Voltage	15/03/2018	250	V Information
Insulation	15/03/2018	> 19.99	MOhm Pass
Overall: Pass			

Asset ID: 97123	Description: FAN HEATER	Make: HIGHLANDS	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	
Test Type	Date	Result	Unit Status
Plug	15/03/2018		Pass
Flex	15/03/2018		Pass
Enclosure	15/03/2018		Pass
Environment	15/03/2018		Pass
Socket	15/03/2018		Pass
Switch	15/03/2018		Pass
Voltage	15/03/2018	230	V Information
Insulation Voltage	15/03/2018	250	V Information
Insulation	15/03/2018	> 19.99	MOhm Pass
Overall: Pass			

Asset ID: 97124	Description: PHONE CHARGER	Make: MICROSOFT	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	
Test Type	Date	Result	Unit Status
Plug	15/03/2018		Pass
Flex	15/03/2018		Pass
Enclosure	15/03/2018		Pass
Environment	15/03/2018		Pass
Socket	15/03/2018		Pass
Switch	15/03/2018		Pass
Voltage	15/03/2018	230	V Information
Insulation Voltage	15/03/2018	250	V Information
Insulation	15/03/2018	> 19.99	MOhm Pass
Overall: Pass			

Signed By: 

Test Certificate

Testing Date RangeFrom: 15/03/2018 To: 15/03/2018
***Note - Items were not function tested**

Asset ID: 97125	Description: PHONE CHARGER	Make: APPLE	Model:
User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:	

Test Type	Date	Result	Unit	Status
Plug	15/03/2018			Pass
Flex	15/03/2018			Pass
Enclosure	15/03/2018			Pass
Environment	15/03/2018			Pass
Socket	15/03/2018			Pass
Switch	15/03/2018			Pass
Voltage	15/03/2018	230	V	Information
Insulation Voltage	15/03/2018	250	V	Information
Insulation	15/03/2018	> 19.99	MOhm	Pass

Overall: Pass

User: NICK	Test Instrument: Seaward Apollo 600 11H-0311	Comments:
------------	--	-----------

Total Tests: 20

Signed By: 